



**SPECIFICATION**

SIZE	50~200
PRESSURE	20K
TEMP/°C	-29~220
TEST/MPa	SEALING(WATER) 1.31
	STRENGTH(WATER) 5.3
MEDIUM	WATER/STEAM/OIL

**TECHNICAL REQUIREMENTS**

- 1.DESIGN: KS B 2361;
- 2.FLANGEN END: JIS10K;
- 3.TESTING: KS B 2304.

D	D <sub>1</sub>	D <sub>2</sub>	DN	N×Ød	L	B	H
DN50	Ø120	Ø96	Ø50	8×Ø19	267±2	22	164.5
DN65	Ø140	Ø116	Ø65	8×Ø19	292±2	24	166.5
DN80	Ø160	Ø132	Ø80	8×Ø23	318±2	26	184
DN100	Ø185	Ø160	Ø100	8×Ø23	356±2	28	219.5
DN125	Ø225	Ø195	Ø125	8×Ø25	400±2	30	239.5
DN150	Ø260	Ø230	Ø150	12×Ø25	444±2	32	299
DN200	Ø350	Ø275	Ø200	12×Ø25	533±2	34	367

NO.	NAME	QTY.	MATERIAL
11	PLUG		25 STEEL
10	PIN		STS 304
9	NUT		SM25C(25)
8	BOLT		SM35C(35)
7	BONNET		SCPH2(WCB)
6	GASKET		STEEL+GRAPHTE
5	NUT		SS400(25)
4	SPRING GASKET		S80C-CSP(65Mn)
3	HINGE PIN		SCPH2(WCB)
2	DISC		SSC1(WCB)
1	BODY		SCPH2(WCB)

YUANDA VALVE	
GROUP CO.,LTD	
KS STEEL CHECK VALVE	
50~200YDSC20K	